ADDENDUM NO. 2

CITY OF HIALEAH 36 UNIT ELDERLY HOUSING 355 EAST 32nd STREET HIALEAH, FLORIDA

FEBRUARY 28, 2013

TO ALL CONCERNED

The original Contract Documents, for the Project entitled CITY OF HIALEAH – 36 Unit Elderly Housing, CERAMIC, PORCELAIN AND VINYL TILE BID NO. 2012/13-3230-00-018 is hereby amended as noted in this Addendum No. 2.

This Addendum No. 2 consists of 1 Typed Pages, 0 Sketches, 0 Attachments and 0 Drawings. All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:		Date:	February 28, 2013	
	Luis Azan - Project Manager		-	

ACKNOWLEDGEMENT

Receipt of this **Addendum No. 2** shall be acknowledged in the space provided on the ADDENDUM RECEIPT FORM (ARF) (copy attached) now a part of the Contract Documents faxed immediately to City of Hialeah @ (305) 687-2642, and submitted with sealed bids.

IN THE CONTRACT DOCUMENTS:

Response to RFI from *The Tile Store* dated February 24, 2013:

1. Does The Thin Set at the Balconies have to be waterproof?

Yes

2. Does the Thin Set at hallways have to be waterproof?

Yes

3. Finish Schedule on AA-4.2 shows Tile Floor and Wood Base at the Great Room and Kitchen. Is the Tile owner provided or do we supply for these areas?

City is to provide the tile for these areas.

4. Finish Schedule on AA-7.2 shows Tile Floor and Tile Base at the Janitor. Is the Tile owner provided or do we supply for this area?

City is to provide tile for the Janitor's Room. 4" tile base is to be cut from City provided tile.

5. Detail A on AA-5.1 Shows a ceiling height of 7'-0" at Unit Baths. Finish Schedule on AA-4.1 shows a ceiling height of 7'-8"

Unit bathrooms have a soffit area which may vary slightly. The Maximum ceiling height is to be 7'-8".

CERAMIC, PORCELAIN AND VINYL TILE -BID #2012/13-3230-00-018

PAGE 1 OF 1 END OF ADDENDUM NO. 2

ADDENDUM RECEIPT FORM

CITY OF HIALEAH 36 UNIT ELDERLY HOUSING 355 EAST 32ND STREET HIALEAH, FLORIDA

CONTRACTOR'S NAME		
ADDRESS		
PHONE NO	FAX NO.	
CONTACT NAME	SIGNATURE	
	EDGES RECEIPT OF THE FOLLOW DPY OF THIS FORM MUST BE FAXE 42.	·
<u>ADDENDUM</u>	<u>SIGNATURE</u>	DATE
2		

CERAMIC, PORCELAIN AND VINYL TILE-BID #2012/13-3230-00-018

ARF